

**ANALYSERAPPORT**
**53563/12**

 Nybrovejens Vandværk  
 Nybrovejen 15  
 3550 Slangerup  
 David Ipsen

 Udskrevet: 26-06-2012  
 Version: 1  
 Udtaget: 12-06-2012 14.00  
 Modtaget: 12-06-2012  
 Påbegyndt: 12-06-2012  
 Udtaget af: Lab/CAN

**Råvand**

**Sagsnummer:** Nybrovejens vandværk, Nybrovejen 15  
**Kunde:** Nybrovejens Vandværk, Nybrovejen 15, 3550 Slangerup  
**Prøvested:** Nybrovejens vandværk, Nybrovejen 15, DGU 192.1200, , Slangerup  
**Prøvetype:** Boringskontrol,

**RESULTATER FOR PRØVE 53563/12**

Parameter	Resultat	Enhed	Metode
FELTMÅLINGER:	:	-	-
Temperatur ved prøveudtagning	8.5	°C	-
Iltindhold ved prøveudtagning	1.65	mg/l	-
LABORATORIEUNDERSØGELSE	:	-	-
Ledningsevne	68	mS/m	DS 288
pH	7.5	pH	DS 287,AK.26
Ammonium, NH4+	0.165	mg/l	DS 224,MOD AK 165
Nitrit, NO2-	<0.0016	mg/l	DS 222,MOD AK 165
Nitrat, NO3-	0.058	mg/l	DS 222+223,MOD,AK165
Fluorid, F-	0.20	mg/l	DS 218,MOD
Jern, Fe	3.3	mg/l	SM 17udg,3120B
Mangan, Mn	0.16	mg/l	SM 17udg,3120B
Natrium, Na+	12	mg/l	SM 17udg,3120B
Kalium, K+	1.8	mg/l	SM 17udg,3120B
Calcium, Ca++	122	mg/l	SM 17udg,3120B
Magnesium, Mg++	8	mg/l	SM 17udg,3120B
Hydrogencarbonat, HCO3-	325	mg/l	DS 253
Sulfat, SO4--	68	mg/l	SM17udg,1989 4500
Inddampningsrest	468	mg/l	DS 204
Aggressiv kuldioxid, CO2	<2	mg/l	DS 236
Hydrogensulfid, H2S	<0.01	mg/l	DS 278
NVOC	3.2	mg/l	SM 17udg,5310 C
Total phosphor, P	0.046	mg/l	DS/EN ISO 6878:2004
Chlorid, Cl-	23	mg/l	DS/EN ISO 15682:2001
Bor, B	20	µg/l	SM 17udg,3120B
Arsen, As	0.15	µg/l	ICP/MS
Barium, Ba	11	µg/l	ICP/MS
Kobolt, Co	0.13	µg/l	ICP/MS
Nikkel, Ni	1.1	µg/l	ICP/MS
Methan, CH4	<0.01	mg/l	GC/FID/vand AK.65
2,4-dichlorphenol	<0.010	µg/l	GC/MS AK158
2,6-dichlorphenol	<0.010	µg/l	GC/MS AK158
Pesticider, Drikkevand grundpakke	i.p.	-	GC/LC/MS
Mechlorprop(MCPP)	<0.010	µg/l	LC/MS/SIM AK: 78
MCPA	<0.010	µg/l	LC/MS/SIM AK. 78
Dichlorprop(2,4-DP)	<0.010	µg/l	LC/MS/SIM AK. 78
2,4-D	<0.010	µg/l	LC/MS/SIM AK. 78
Simazin	<0.010	µg/l	LC/MS/SIM AK. 78
Atrazin	<0.010	µg/l	LC/MS/SIM AK. 78
Dichlobenil	<0.010	µg/l	GC/MS/SIM AK. 78
4-Chlorprop (4-CPP)	<0.010	µg/l	LC/MS/SIM AK. 78
2,6-Dichlorprop (2,6-DCPP)	<0.010	µg/l	LC/MS/SIM AK. 78
Desisopropylatrazin	<0.010	µg/l	LC/MS/SIM AK. 78
Desethylatrazin	<0.010	µg/l	LC/MS/SIM AK. 78
Hydroxyatrazin	<0.010	µg/l	LC/MS/SIM AK. 78
2,6-Dichlorbenzamid (BAM)	<0.010	µg/l	LC/MS/SIM AK. 78

Bentazon		<0.010	µg/l	LC/MS/SIM AK. 78
Hexazinon		<0.010	µg/l	LC/MS/SIM AK. 78
ETU (Ethylthiourea)	#	<0.010	µg/l	LC/MS/SIM AK. 78
Aminomethylphosphorsyre, AMPA		<0.010	µg/l	LC/MS/SIM AK144
Desethyl-desisopropylatrazin	#	<0.010	µg/l	LC/MS/MS AK189
Desethyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189
Desisopropyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189
2,6-dichlorbenzoesyre	#	<0.010	µg/l	LC/MS/MS AK189
Didealkyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189
Desethylterbutylazin		<0.010	µg/l	LC/MS/SIM AK. 78
Glyphosat		<0.010	µg/l	LC/MS/SIM AK144
Hydroxysimazin		<0.010	µg/l	LC/MS/SIM AK. 78
4-nitrophenol		<0.010	µg/l	LC/MS/SIM AK.78

## KOMMENTARER

Ingen kommentar



Mikkel West-Nørager

Kopi sendt til:

Sundhedsstyrelsen, Borups Allé 177, 4., 2400 København NV  
Frederikssund Kommune Natur og miljø (vandforsyninger), Torvet 2, 3600 Frederikssund